

Determining Voltage Stability Margin Values by Measuring the Hypotenuse Under PV and QV Curves

Ahmad Fateh Mohamad Nor*, Marizan Sulaiman, Aida Fazliana Abdul Kadir and Rosli Omar

Center for Robotics and Industrial Automation (CeRIA)

Fakulti Kejuruteraan Elektrik, Universiti Teknikal Malaysia Melaka

*corresponding author: ahmadfatehmohamadnor@gmail.com

Abstract – Voltage instability is one of the main causes of electrical power system blackouts all around the world. Voltage instability can be analyzed with the used of PV and QV curves technique. From these curves, the values of voltage stability margin (VSM) can be determined. VSM is very important in analyzing voltage instability because it shows the distance of how far the power system is able to run before experiencing voltage instability. This paper presents the calculation of VSM values by measuring the hypotenuse under the PV and QV curves. These VSM values are used to determine the weakest bus in the power system. Then, these values are compared with the VSM values that are being calculated using the conventional equation. The IEEE 14-bus power system has been chosen as the reference electrical power system.

Keywords: Voltage instability analysis; Voltage stability margin; PV and QV curves; IEEE 14-bus power system

Article History

Received 23 November 2017

Received in revised form 12 January 2018

Accepted 30 January 2018

I. Introduction

Since the 1920s, the instability of electrical power system has been recognized as one of the main problems in power systems operation [1]. Voltage instability in one of the categories that falls under electrical power system instability. Previous events of blackouts occurred around the world show that voltage instability is one of the main cause of power system blackouts [2–6]. Voltage instability can be defined as the failure of an electrical power system to sustain the voltage magnitudes at all buses remain the same after the electrical power system is being exposed to a disturbance [7–9]. It occurs due to the failure of the electrical power system to supply ample power to cover the increased demand of load. Currently, the increase in electrical power demand has forced the operation of electrical power systems to operate very close to the instability limits [10,11]. Therefore, the analysis of voltage instability in electrical power systems is of paramount importance so that the electrical power systems always operate within the allowable range (far from the instability limit).

Most of the literatures [2,12–14] have stated that one of the most common methods of voltage instability analysis is the power-voltage (PV) curve and reactive power-voltage (QV) curve method. These curves can be generated by generating a series of power flow. For every series of power flow, the load of the electrical power system is increased until the point where the system is not

able to operate any longer. The variation values of real power (P) and reactive power (Q) with the value of load is plotted as the PV and QV curve, respectively. Both PV and QV curves give the values of voltage stability margin (VSM). VSM values are very important because they point out the distance of how far the power system is able to run before experiencing voltage instability [7,15,16]. A weak bus is a bus that is closed towards experiencing voltage instability [17]. It cannot afford a large increase of load demand especially reactive power (Q) of load [18,19].

Lower value of VSM conveys that the closer of the bus towards experiencing voltage instability and vice versa. The expression to calculate the VSM by following [9,15,20] is given as,

$$VSM = \frac{V_{initial} - V_{critical}}{V_{critical}}, \quad (1)$$

Where

$V_{initial}$ and $V_{critical}$ is the bus voltage at initial and critical operating point, respectively.

Note that (1) did not take the load increment values into account. This will result in the possibility of two load buses with dissimilar situation (one strong/stable bus and another bus is weak bus) to have a same or close VSM value. For instance, assume that there are two load buses namely Bus X and Bus Y in a power system. Both Bus X and Bus Y have the same value of $V_{initial}$ and $V_{critical}$ which

are 1.0 per unit and 0.6 per unit, respectively. Based on (1) both Bus X and Bus Y will have the same VSM value which is 0.67 per unit. However, the load increment value at Bus X is 10 times the initial load value before reaching $V_{critical}$ value (0.6 per unit). On the other hand, the load at Bus Y can only be increase 4 times before reaching $V_{critical}$ value (0.6 per unit). This means that Bus Y is closer towards experiencing voltage instability compared to Bus X even though they both have the same VSM value. To overcome this issue, the VSM values in this research will be calculated by measuring the hypotenuse distance of the triangle under the PV and QV curves.

II. Methodology

A. Generation of PV and QV Curves

The methodological steps of plotting the PV and QV curves for the load buses are listed as follows [8,21]:

- i. Run the power flow for the electric power system (IEEE-14 bus in this paper) by using Power World Simulator.
- ii. Increase the value of P load at the load bus by 0.1 per unit in order to plot PV curve. Similarly, increase the value of Q load by 0.1 per unit in order to plot QV curve. Then run the power flow program again. A new voltage value at the selected bus will be obtained. Record the values of P or Q and the corresponding load bus voltage values.
- iii. Repeat step (ii) until the value of desired P or Q cannot be delivered by the system.
- iv. Lastly, use all the recorded value of P or Q obtained in previous steps and plot it against the voltage values of the selected load bus.

In this research, the incremental values of P of load (ΔP) and Q of load (ΔQ) to the system experiencing voltage instability are recorded. This is to identify the relationship between the VSM values with the load increment values.

B. Voltage Stability Margin

VSM can be defined as the distance between the initial voltage operating point until the voltage critical point [22]. Based on this definition, VSM should be calculated by measuring the hypotenuse distance of a triangle that can be formed under the PV and QV curves as shown in Fig. 1 and Fig. 2 [15,22]. VSM can be divided into two categories. The first one is VSM for real power of load (P) and the second one is VSM for reactive power of load (Q) which is denoted as $VSM(P)$ and $VSM(Q)$, respectively. $VSM(P)$ is available from the PV curve as shown in Fig. 1. Let $V_{Pinitial}$ and $V_{Pcritical}$ is the bus voltage at initial and critical operating point, respectively. Let also $P_{critical}$ and $P_{initial}$ is the value of real power of load at voltage critical point and initial operating point, respectively. Hence, $VSM(P)$ can be calculated as




Fig. 1. $VSM(P)$ in PV Curve

$$VSM(P) = \sqrt{a^2 + b^2}, \quad (2)$$

where $a = V_{Pinitial} - V_{Pcritical}$ and $b = P_{initial} - P_{critical}$. Note that ΔP is the highest value of P load that can be achieved before the system facing voltage instability. Thus, ΔP is given by

$$\Delta P = P_{critical} - P_{initial}. \quad (3)$$

Similarly, $VSM(Q)$ is obtained from the QV curve as displayed in Fig. 2. Let $V_{Qinitial}$ and $V_{Qcritical}$ is the bus voltage at initial operating point and critical point, respectively. Let also $Q_{initial}$ and $Q_{critical}$ is the value of reactive power of load at initial operating point and voltage critical point, respectively. Hence, $VSM(Q)$ can be calculated as

$$VSM(Q) = \sqrt{c^2 + d^2} \quad (4)$$

where $c = V_{Qinitial} - V_{Qcritical}$ and $d = Q_{initial} - Q_{critical}$. Note that ΔQ is the highest value of Q load that can be achieved before the system facing voltage instability. Hence, ΔQ can be determined as

$$\Delta Q = Q_{critical} - Q_{initial} \quad (5)$$

It is very clear from both Fig. 1 and Fig. 2 that smaller VSM values will cause the distance between the load buses towards voltage instability becomes closer and vice versa.




Fig. 2. $VSM(Q)$ in QV Curve




Fig. 3. IEEE 14-bus system

C. The IEEE 14-bus System

Fig. 3 shows the IEEE 14-bus system [23]. In this system, Bus 1 is the slack bus, Bus 2, Bus 3, Bus 6 and Bus 8 are the voltage-controlled buses, and the remaining buses (Bus 4, Bus 5, Bus 7 and Bus 9 until Bus 14) are the load buses. Load buses is very important in voltage stability analysis because PV and QV curve are generated at load buses. The load flow analyses are done by using Power World Simulator software version 16. In this research, only constant power load are considered since this type of load is favourable to voltage instability [8].

III. Results and Discussion

Table 1 lists the $VSM(P)$ values calculated by using both the conventional equation that is based on (1) and by measuring hypotenuse under PV curve. These $VSM(P)$ values are also compared with the incremental values of P load (ΔP). ΔP stands for the maximum value of P load that can be increased before the system experiencing voltage instability. To facilitate the observation process, Fig. 4 illustrates the ΔP from the lowest to the highest value.

From Table 1 and Fig. 4, it indicates that Bus 14 has the lowest value of ΔP compared to the rest of the buses. This means Bus 14 is the weakest bus in the IEEE-14 bus system. The weakest bus means that the bus has the highest tendency towards experiencing voltage instability since it cannot afford high incremental value of P load. In addition, the P modal analysis technique that has been done in the previous research work [24] has also shown that Bus 14 has the highest tendency towards experiencing voltage instability compared to other buses in the system. Hence, more attention should be given to Bus 14 to make sure that it does not reach the voltage instability limit. Fig. 5 depicts $VSM(P)$ values calculated by using Equation 1 in an ascending order.

As can be seen in Fig. 5, Bus 13 is the weakest bus since it has the lowest $VSM(P)$ value. It is also noticeable from Fig. 5 that Bus 14 is considered one of the most stable buses in the IEEE-14 bus system. This is in contrast with the values of ΔP stated in Table 1 and Fig. 4. Besides that, Fig.

5 also depicts that the $VSM(P)$ value of Bus 4 is similar to the $VSM(P)$ value of Bus 14. Whereas, from Fig. 4, Bus 4 can afford a huge amount of ΔP value. This indicates that the $VSM(P)$ values calculated by using the conventional equation based on (1) are not in synchronisation with the values of ΔP . Fig. 6 depicts $VSM(P)$ values that is calculated by measuring the hypotenuse under the PV curve in an ascending order.

Fig. 6 depicts that Bus 14 is the weakest bus in the IEEE-14 bus system since it has the lowest $VSM(P)$ value. This is in similar with the results in Fig. 4 and results in [24]. In addition, it is observable from Fig. 6 that the ranking of the load buses from the weakest to the strongest are same with the ranking in Fig. 4. This proves that the $VSM(P)$ values calculated by measuring hypotenuse under PV curve are in synchronisation with the values of ΔP .

 TABLE I
VALUES OF ΔP AND $VSM(P)$

Bus	ΔP (per unit)	$VSM(P)$ based on (1)	$VSM(P)$ by measuring the hypotenuse under the PV curve
4	2.9	0.4531	2.9173
5	3.3	0.5354	3.2961
7	1.6	0.3237	1.6209
9	1.4	0.3220	1.4234
10	1.2	0.3574	1.2315
11	1.1	0.3304	1.1309
12	0.9	0.5331	0.9713
13	1.0	0.2530	1.0222
14	0.8	0.4678	0.8654





Fig. 4. The maximum value of P load that can be increased before experiencing voltage instability


 Fig. 5. $VSM(P)$ Values by Using Equation 1




Fig. 6. $VSM (P)$ by measuring the hypotenuse under the PV curve




Fig. 7. The maximum value of Q load that can be increased before experiencing voltage instability

Meanwhile, Table II lists the $VSM (Q)$ values calculated based on (1) and by measuring hypotenuse under QV curve. These $VSM (Q)$ values are also compared with the incremental values of Q load, ΔQ . The ΔQ stands for the maximum value of Q load that can be increased before the system experiencing voltage instability. Thus, to facilitate the observation process, Fig. 7 illustrates the ΔQ from the lowest to the highest value.

Based on Table II and Fig. 7, Bus 14 has the lowest value of ΔQ compared to the rest of the buses. This means Bus 14 is the weakest bus in the IEEE-14 bus system since it cannot afford high incremental value of Q load. In addition, the Q modal analysis technique that has been done in the previous research work [24,25] has also shown that Bus 14 has the highest tendency towards experiencing voltage instability compared to other buses in the system. Hence, more attention should be given to Bus 14 to make sure that it does not reach the voltage instability limit. Fig. 8 depicts $VSM (Q)$ values calculated by using (1) in an ascending order.




Fig. 8. $VSM (Q)$ values based on (1)

Fig. 9 depicts that Bus 14 is the weakest bus in the IEEE-14 bus system since it has the lowest $VSM (Q)$ value. This is in similar with the data in Fig. 7 and in [24]. In addition, it is observable from Fig. 9 that the ranking of the load buses from the weakest to the strongest are same with the ranking in Fig. 7. This proves that the $VSM (Q)$ values calculated by measuring hypotenuse under QV curve are in synchronisation with the values of ΔQ .

As can be seen in Fig. 8, Bus 13 is the weakest bus since it has the lowest $VSM (Q)$ value. This is in contrast with the data listed in Table 2 and Fig. 7. Besides that, Fig. 8 also depicts that the $VSM (Q)$ value of Bus 4 is similar to the $VSM (Q)$ value of Bus 7. Whereas according to Fig. 7, Bus 4 can afford a huge amount of ΔQ value compared to Bus 7. This indicates that the $VSM (Q)$ values calculated based on (1) are not in synchronisation with the values of ΔQ . Fig. 9 depicts $VSM (Q)$ values calculated by measuring the hypotenuse under the QV curve in an ascending order.




Fig. 9. $VSM (Q)$ by measuring the hypotenuse under the QV curve

TABLE II
VALUES OF ΔQ AND $VSM (Q)$

Bus	ΔQ (per unit)	$VSM (Q)$ based on (1)	$VSM (Q)$ by measuring the hypotenuse under the QV curve
4	2.5	0.9930	2.5501
5	2.7	1.0311	2.7321
7	1.2	0.9754	1.3299
9	1.1	0.9084	1.1710
10	0.9	0.8841	1.0230
11	0.8	0.8039	0.9641
12	0.7	0.9404	0.8699
13	0.8	0.8011	0.9574
14	0.6	0.8204	0.7897

IV. Conclusion

Voltage instability analysis is an important parameter for monitoring the bus voltage in the electrical power system. Both $VSM (P)$ and $VSM (Q)$ values are very useful in showing the distance of how far the power system can run before experiencing voltage instability. A load bus is

considered weak if it cannot accept high increased in load. Hence, the values of VSM should be in synchronization with the values of load increment. The research conducted in this paper has successfully showed that the calculation of VSM values by measuring the hypotenuse under PV and QV curves can give better results compared to the previous method. The VSM values calculated by measuring hypotenuse under PV and QV curves are in synchronizations with the load incremental values. In addition, the results have shown that the value of real power (P) at load busses can be increased much more compared to the value of reactive power (Q) of load. increased in reactive power (Q) of load give higher contributions towards voltage instability compared to the increased in real power (P) of load. It is very vital to perform voltage instability analysis especially the calculation of VSM values. This is because accurate VSM values are important to determine the weakest load bus of the power system. Once the weakest load bus has been determined, action can be taken to avoid voltage instability from taking place. The voltage instability has the capability to cause total system black-out. The black-out area caused by voltage instability might spread to one area or even worse, to the whole nation. This can lead to much worse problem especially to the economy.

Acknowledgements

The authors are very grateful to the Universiti Teknikal Malaysia Melaka (UTeM) through the Center of Excellent for Robotics and Industrial Automation (CeRIA) for providing research platform.

References

- [1] P. Kundur, J. Paserba, V. Ajjarapu, G. Andersson, A. Bose, C. Canizares, N. Hatziaiyriou, D. Hill, A. Stankovic, C. Taylor, T. Van Cutsem, Definition and Classification of Power System Stability, *IEEE Transactions on Power Systems*, Vol. 19 (Issue 2):1387–1401, 2004.
- [2] G. K. Morison, B. Gao, and P. Kundur, Voltage Stability Analysis using Static and Dynamic Approaches, *IEEE Transactions on Power Systems*, Vol.8, (Issue 3): 1159–1171, 1993.
- [3] S. G. Ghiocel and J. H. Chow, A Power Flow Method Using a New Bus Type for Computing Steady-State Voltage Stability Margins, *IEEE Transactions on Power Systems*, Vol. 29, (Issue 2):958–965, 2014.
- [4] N. Palukuru, S. Halder Nee Dey, T. Datta, and S. Paul, Voltage Stability Assessment of a Power System Incorporating FACTS Controllers Using Unique Network Equivalent, *Ain Shams Engineering Journal*, Vol.5, (Issue 1):103–111, 2014.
- [5] B. Poornazaryan, P. Karimyan, G. B. Gharehpetian, and M. Abedi, Optimal Allocation and Sizing of DG Units Considering Voltage Stability, Losses and Load Variations, *International Journal of Electrical Power and Energy Systems*, Vol.79:42–52, 2016.
- [6] Y. A. Mobarak, Voltage Collapse Prediction for Egyptian Interconnected Electrical Grid EIEG, *International Journal on Electrical Engineering and Informatics*, Vol.7, (Issue 1):79–88, March 2015.
- [7] H. H. Goh, Q. S. Chua, S. W. Lee, B. C. Kok, K. C. Goh, and K. T. K. Teo, Evaluation for Voltage Stability Indices in Power System Using Artificial Neural Network, in *International Conference on Sustainable Design, Engineering and Construction Evaluation*, 2015, Vol. 118, pp. 1127–1136.
- [8] M. Sulaiman, A. F. M. Nor, and N. R. Bujal, Voltage Instability Analysis on PV and QV Curves for Radial-Type and Mesh-Type Electrical Power Networks, *International Review of Electrical Engineering (I.R.E.E.)*, Vol.10, (Issue 1):109–115, 2015.
- [9] A. F. M. Nor, M. Sulaiman, A. F. A. Kadir, and R. Omar, Voltage Instability Analysis for Electrical Power System Using Voltage Stability Margin and Modal Analysis, *Indonesian Journal of Electrical Engineering and Computer Science*, Vol.3, (Issue 3): 655–662, 2016.
- [10] G. Nannapaneni, S. Member, T. M. Masaud, and R. Challoo, A Comprehensive Analysis of Voltage Stability Indices in the Presence of Distributed Generation, *2015 IEEE Conference on Technologies for Sustainability (SusTech)*, pp. 96–102, 2015.
- [11] L. Zhu, C. Lu, and Y. Sun, Time Series Shapelet Classification Based Online Short-Term Voltage Stability Assessment, *IEEE Transactions on Power Systems*, Vol.31, (Issue 2):1430–1439, 2016.
- [12] N. R. Bujal, A. E. Hasan, and M. Sulaiman, Analysis of Voltage Stability Problems in Power System, *4th International Conference on Engineering Technology and Technopreneuship (ICE2T)*, pp. 278–283, 2014.
- [13] O. Alizadeh Mousavi and R. Cherkaoui, Investigation Of P–V And V–Q Based Optimization Methods for Voltage and Reactive Power Analysis, *International Journal of Electrical Power & Energy Systems*, (Vol.63): 769–778, Dec. 2014.
- [14] A. F. M. Nor, M. Sulaiman, A. F. A. Kadir, and R. Omar, Classifications of Voltage Stability Margin (VSM) And Load Power Margin (LPM) Using Probabilistic Neural Network (PNN), *ARPN Journal of Engineering and Applied Sciences*, Vol.12, (Issue 19):5591–5596, 2017.
- [15] S. Basu, C. Gupta, and S. Chowdhuri, Voltage Stability Margin (VSM) and Maximum Loading Point (MLP) Of A Multi-Bus System Before and After Compensation, *International Journal of Engineering Research and Development*, Vol.5, (Issue 7): 30–35, 2013.
- [16] D. Q. Zhou, U. D. Annakkage, and A. D. Rajapakse, ‘Online Monitoring of Voltage Stability Margin Using an Artificial Neural Network’, *IEEE Transactions on Power Systems*, Vol.25, (Issue 3): 1566–1574, 2010.
- [17] N. F. A. Aziz, N. A. Rahmat, F. M. Sukki, T. K. A. Rahman, Z. M. Yassin, N. A. Wahab, and N. A. Salim, A New Weak Area Identification Method in Power System Based on Voltage Stability, *Journal of Telecommunication, Electronic and Computer Engineering (JTEC)*, Vol.9, (Issue 2): 171–177, 2017.
- [18] S. D. Naik, M. K. Khedkar, and S. S. Bhat, Effect of Line Contingency on Static Voltage Stability and Maximum Loadability In Large Multi Bus Power System, *International Journal of Electrical Power and Energy Systems*, Vol.67, : 448–452, 2015.
- [19] R. Kumar, A. Malik, and G. Dalakoti, Power Flow & Voltage Stability Analysis using MATLAB, *International Research Journal of Engineering and Technology (IRJET)*, Vol.4, (Issue 1) : 93–99, 2017.
- [20] K. Chakraborty and S. Das Biswas, An Offline Simulation Method to Identify the Weakest Bus and Its Voltage Stability Margin in a Multibus Power Network, *International Conference MS’07*, pp. 1–5, December 2007.
- [21] B. Aydin, *Voltage Security Assessment Using P-V and Q-V Curves*, Bahcesehir University, 2008.
- [22] A. R. Bahmanyar and A. Karami, Power System Voltage Stability Monitoring Using Artificial Neural Networks with A Reduced Set of Inputs, *International Journal of Electrical Power & Energy Systems*, Vol.58: 246–256, 2014.
- [23] M. A. Pai, *Computer Techniques in Power System Analysis*, Second Edition. (New Delhi: Tata McGraw-Hill, 2006).
- [24] A. F. M. Nor and M. Sulaiman, Voltage Stability Assessment of Power System Network using QV and PV Modal Analysis, *Journal of Telecommunication, Electronic and Computer Engineering (JTEC)*, Vol.8, (Issue 7): 7–11, 2016.
- [25] B. Telang and P. Khampariya, Voltage Stability Evaluation Using Modal Analysis, *International Journal of Scientific Research Engineering & Technology (IJSRET)*, Vol.4, (Issue 4): 408–411, 2015.

